



SAFETY AND BUILDINGS DIVISION
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor
Dave Ross, Secretary

April 30, 2014

ECOLAB, INC.
REGULATORY AFFAIRS
JAMISON KORTAS
370 N. WABASHA ST.
ST. PAUL MN 55102-1390

ECOLAB, INC.
INSTITUTIONAL
ANI SEUMALO
370 N. WABASHA ST.
ST. PAUL MN 55102

Re: Description: PROPORTIONER
Manufacturer: ECOLAB, INC.
Product Name: ECOLAB PRODUCT DISPENSERS FOR MANUAL WAREWASHING
Model Number(s): AS-1; GEO II HYDRAULIC PRESOAK; GEO II SOLID RINSE ADDITIVE; GEO II ELECTRONIC POT AND PAN; GEO II HYDRAULIC POT AND PAN; AND GEO II DETERGENT
Product File No: 20140057

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.11 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2019.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This alternate approval allows for the use of chemical proportioners that are not listed under ASSE Standard 1055.
- This alternate approval is contingent upon the AS-1 model being installed using the Watts N-388 SR atmospheric vacuum breaker (AVB). The Geo II Hydraulic Presoak, Geo II Solid Rinse Additive, Geo II Electronic Pot and Pan, Geo II Hydraulic Pot and Pan and Geo II Detergent models being installed using the Ecolab A25-F AVB. Both the Watts 388SR and Ecolab A-25F AVBs conform to ASSE 1001 and are listed by ASSE. The AVBs must be installed in accordance with s. SPS 382.41 (4) (b) 1.
- All proportioners shall be installed in accordance with 382.41 (5) (k).

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail